


**SUMMARY OF RESULTS  
OF TESTING CERTIFICATE 10119 / 20.12.2010**

<b>NUMBER</b>	<b>10119</b>	<b>DATE</b>	<b>20 / 12 / 2010</b>
---------------	--------------	-------------	-----------------------

<b>Client' s data:</b>	<b>ETEM S.A.</b> <b>LIGHT METALS COMPANY</b> 1, IROON POLYTEHNIU STR. GR 196 00 MAGOULA ATTIKIS - GREECE
<b>Product description:</b>	<b>Double Sash Balcony Door</b> <b>With One Fixed Sash</b> <b>Lift &amp; Slide</b>
<b>Material:</b>	<b>ALUMINIUM</b>
<b>System :</b>	<b>E – 52 Thermo</b>



1720 x 2200mm

<b>Air Permeability</b> <i>ELOT EN 1026:2000 / ELOT EN 12207:2000</i>	<b>Class 4</b>
<b>Watertightness</b> <i>ELOT EN 1027:2000 / ELOT EN 12208:2000</i>	<b>Class 6A</b>
<b>Resistance to Wind Load</b> <i>ELOT EN 12211:2000 / ELOT EN 12210:2000</i>	<b>Class C2 / B3</b>

THE RESULTS CONCERN EXCLUSIVELY THE ABOVE TESTED PRODUCT.



**SINOPI PAPADOPOULOU**  
**LABORATORY MANAGER**



**IOANNIS GKERTSOS**  
**GENERAL MANAGER**

EXACT TRANSLATION FROM THE GREEK ORIGINAL